



Building Department

UES – UCFBD Delineation

The following UES delineation points apply to all projects, unless a sidewalk or parking lot beyond the agreed upon point is impacted.

UES Service	UCFBD jurisdiction begins at:
Potable Water*	Backflow meter assembly to the building, or group of buildings
Reclaimed Water*	Booster station
Sanitary Sewer	First manhole outside the building or group of buildings
Storm Water Collection-	First manhole outside the building or group of buildings
Primary Power -	600VAC bushing on the load side of the Duke Energy Transformer
Hot Water Heating -	First isolation valve outside the building or group of buildings
Chilled Water-	First isolation valve outside the building or group of buildings
Natural Gas-	First isolation valve outside the building or group of buildings

* All backflow preventer applications, not in buildings specifically covered by the Annual Facilities Permit, require permitting.